

Attestation

BREEAM®

On 21st of May 2024 Eurofins Product Testing A/S received a sample of paint with the product name:

BOERO HP SATINATO

supplied by

Boero Bartolomeo S.p.A.

The sample was supplied as being representative of the manufactured product, and it has been tested as in accordance with the relevant EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, and ISO 16000-11 and ISO 11890-2 testing standards (See test report no. 392-2024-00241806_A_EN and no. 392-2024-00241812_XG_EN).

The test results of the tested sample indicate that the product qualifies for the below mentioned BREEAM specifications on VOC emissions and VOC content by complying with:

- **BREEAM® International: Compliance with 'Exemplary' criteria on VOC emission and VOC content** of BREEAM International: New Construction 2021, Technical Manual – SD250: Hea 02 Indoor Air Quality (version 6.0. of December 2021).
- **BREEAM® UK: Compliance with 'Exemplary' criteria on VOC emission and VOC content** of BREEAM UK: New Construction 2023, Technical Manual: Hea 02 Indoor Air Quality (version SD5079 issue 6.1 of June 2023).
- **BREEAM® NL: Compliance with 'Exemplary' criteria on VOC emission and VOC content** of BREEAM NL: Nieuwbouw en Renovatie Woningen 2023, Technical Manual: Hea 03 Gezonde binnenlucht (Version 1.01 of June 2023). (Version 1.01 of June 2023).
- **BREEAM® SE: Compliance with 'Exemplary' criteria on VOC emission and VOC content** of BREEAM SE: New Construction 2021, Technical Manual: Hea 02 Indoor Air Quality (version 6.0. of January 2023).
- **BREEAM® NOR: Compliance with 'Exemplary' criteria on VOC emission and VOC content** of BREEAM NOR: New Construction 2023, Technical Manual - SD5076NOR, Hea 02 Indoor Air Quality (version 6.1 of November 2023).

31 July 2024


Frederik Foged Haugaard
Analytical Service Manager


Laura Hartung Sørensen
Analytical Service Manager