Attestation

Italian CAM

On 7th of March 2025, Eurofins Product Testing A/S received a sample of a water-based paint with the product name:

BIOSETA ACQUA

supplied by

BOERO BARTOLOMEO Spa

The emissions were tested according to the Italian CAM Decreto Ministeriale 24 novembre 2025 – Criteri Ambientali Minimi per l'edilizia. Sampling, testing, and evaluation were performed according to ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 (see the test report no. 392-2025-00123004_W_EN).

Evaluation of the emission test result according to Italian CAM Premium Score:

- The relevant CMR compounds were not detectable after 28 days.
- The sum of VOC ("TVOC") after 28 days was compliance with the limit of < 500 µg/m³.
- Formaldehyde after 28 days was compliance with the limit of < 10 µg/m³.
- Acetaldehyde after 28 days was compliance with the limit of < 100 µg/m³.
- Toluene after 28 days was compliance with the limit of < 150 µg/m³.
- Tetrachloroethylene after 28 days was compliance with the limit of < 120 µg/m³.
- Xylene after 28 days was compliance with the limit of < 100 µg/m³.
- 1,2,4-Trimethylbenzene after 28 days was compliance with the limit of < 500 µg/m³.
- 1,4-Dichlorobenzene after 28 days was compliance with the limit of < 30 µg/m³.
- Ethylbenzene after 28 days was compliance with the limit of < 350 µg/m³.
- 2-Butoxyethanol after 28 days was compliance with the limit of < 1000 µg/m³.
- Styrene after 28 days was compliance with the limit of < 120 µg/m³.

9 March 2026

Claus Bonde
Analytical Service Manager