

Attestation

LEED v4, v4.1 BETA, and v5

On the 26th of February 2026, Eurofins Product Testing A/S received a sample of a water-based paint with the product name:

BOERO70

supplied by

BOERO BARTOLOMEO Spa

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, EN 16516, and ISO 11890-2 testing standards (See test report no. 392-2026-00108201_A_EN and no. 392-2026-00108202_XG_EN).

The test results of the tested sample indicate that the product qualifies for LEED v4, LEED v4.1 BETA (November 2025), and LEED v5 (November 2025) projects in Europe by showing compliance with the specifications for VOC emissions and VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects in Europe:

- The requirements of LEED v4.1 BETA (November 2025) and LEED v5 (November 2025) by complying with the German AgBB Testing and Evaluation Scheme (2024), showing an overall R-value ≤ 1 , having a TVOC according to EN 16516 $\leq 1,000 \mu\text{g}/\text{m}^3$, a sum of VOC without LCI $< 100 \mu\text{g}/\text{m}^3$, and a formaldehyde emission $\leq 10 \mu\text{g}/\text{m}^3$; all after 28 days.
- The requirements of LEED v4 and LEED v4.1 BETA by complying with:
 - The requirements of Indoor Air Comfort Gold v2026 (January 2026).

VOC content specifications in LEED EQ credit "Low-Emitting Materials" for LEED projects in Europe:

- The requirements of LEED v4 and LEED v4.1 BETA (November 2025): EU Decopaint Directive 2004/42/CE for 'Interior matt walls and ceilings, WB' having a VOC content below 30 g/L.

6 May 2026



Claus Bonde
Analytical Service Manager



Rasmus Verdier
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.